



## **Roy S. Nelson Generating Station Unit 6**

### **Bottom Ash System Evaluation**



**Report SL-016282**

Revision 1, For Information  
December 22, 2025

S&L Project No.: 13603.006

Prepared by



55 East Monroe Street  
Chicago, IL 60603-5780 USA  
312-269-2000  
[www.sargentlundy.com](http://www.sargentlundy.com)

### **LEGAL NOTICE**

This report ("Deliverable") was prepared by Sargent & Lundy, L.L.C. ("S&L"), expressly for the sole use Entergy Louisiana, LLC ("Entergy"). This Deliverable was prepared using the degree of skill and care ordinarily exercised by engineers practicing under similar circumstances. Entergy acknowledges: (1) S&L prepared this Deliverable subject to the particular scope limitations, budgetary and time constraints, and business objectives of Entergy; (2) information and data provided by others may not have been independently verified by S&L; and (3) the information and data contained in this Deliverable are time sensitive and changes in the data, applicable codes, standards, and acceptable engineering practices may invalidate the findings of this Deliverable. Any use or reliance upon this Deliverable by third parties shall be at their sole risk.

## RS NELSON PLANT UNIT 6

### BOTTOM ASH SYSTEM EVALUATION

#### ISSUE SUMMARY AND APPROVAL PAGE

This is to certify that this report has been prepared, reviewed and approved in accordance with Sargent & Lundy's Standard Operating Procedure SOP-0405, which is based on ANSI/ISO/ASSQC Q9001 Quality Management Systems.

<u>Rev.</u>	<u>Purpose of Issue</u>	<u>Date</u>	<u>Sections Affected</u>
0	Issued for Use	11/03/21	All
1	Updated for 2025 Operation	12/22/25	ES, 1, 2, and 4

	<u>Civil/Structural Input</u> <u>Prepared By</u>	<u>Mechanical Input</u> <u>Prepared By</u>	<u>Environmental Input</u> <u>Prepared By</u>	
	Rev 1 – N/A	Rev 1 – N/A	Matthew Heermann Matthew Heermann 2025.12.22 13:12:36 -06'00'	

	<u>Civil/Structural Input</u> <u>Reviewed By</u>	<u>Mechanical Input</u> <u>Reviewed By</u>	<u>Environmental Input</u> <u>Reviewed By</u>	
	Rev 1 – N/A	Rev 1 – N/A	Ken Snell Kenneth Snell Digitally signed by Kenneth Snell Date: 2025.12.22 14:59:47 -06'00'	

<u>Rev.</u>	<u>Reviewed By</u>	<u>Approved By</u>
1	Mike Murray Digitally signed by Michael A Murray Date: 2025.12.22 13:38:59 -06'00' Adobe Acrobat version: 2024.003.20112	Mike Murray Digitally signed by Michael A Murray Date: 2025.12.22 13:39:18 -06'00' Adobe Acrobat version: 2024.003.20112

**RS NELSON PLANT UNIT 6**  
**BOTTOM ASH SYSTEM EVALUATION**

**CERTIFICATION PAGE**

I certify that this report was prepared by me or under my supervision and that I am a registered professional engineer under the laws of the State of Louisiana.

I certify that I am familiar with the 40 CFR 423 regulation requirements and the RS Nelson Facility.

Certified By:

Sean C. McHone

Date:

12/23/2025

Sean C. McHone  
(P.E. No. 37552)

Seal:



---

## RS NELSON PLANT UNIT 6

### BOTTOM ASH SYSTEM EVALUATION

#### TABLE OF CONTENTS

<b>EXECUTIVE SUMMARY .....</b>	<b>1</b>
1. INTRODUCTION AND BACKGROUND .....	3
2. SCOPE OF EVALUATION.....	4
3. THE PRIMARY ACTIVE WETTED BOTTOM ASH SYSTEM VOLUME 40 CFR 423.19(D)(3)(IV) AND 40 CFR 423.19(D)(3)(V).....	4
4. ALL POTENTIAL DISCHARGES 40 CFR 423.19(D)(3)(VI) & 40 CFR 423.19(D)(3)(VII)....	5
5. NARRATIVE DESCRIPTION OF THE WASTEWATER TREATMENT SYSTEM 40 CFR 423.19(D)(3)(VIII) & 40 CFR 423.19(D)(3)(IX) .....	14
<b>APPENDIX A – WETTED BOTTOM ASH VOLUME CALCULATION.....</b>	<b>16</b>
<b>APPENDIX B – BOTTOM ASH SYSTEM RAINFALL ESTIMATION CALCULATION .....</b>	<b>17</b>
<b>APPENDIX C – BOTTOM ASH PURGE WATER SUSPENDED SOLIDS ESTIMATE.....</b>	<b>18</b>
<b>APPENDIX D – WATER BALANCE .....</b>	<b>19</b>

**Note: Drawings in the appendixes have been omitted from the LDEQ submittal package due to confidentiality limitations.**

## EXECUTIVE SUMMARY

The RS Nelson Generating Station Unit 6 (Nelson 6) is a 580 MW Unit, fueled by PRB coal and located in Westlake, Louisiana. Sargent & Lundy (S&L) was retained to evaluate the current status of Nelson's bottom ash system in conjunction with the requirements for discharges of bottom ash transport water (BATW) under the currently applicable Steam Electric Power Generating Effluent Limitations Guidelines and Standards (ELGs) for BATW. *See 40 CFR §423.10 et seq.*

S&L reviewed Nelson 6 drawings and documents to prepare a primary active wetted bottom ash system volume (referred to as the primary wetted volume or "PWV") calculation, evaluated the current system influents and effluents in a water balance, and developed a narrative description of the current wastewater treatment system. As part of this evaluation, S&L evaluated the rainfall volume that can be managed by the system and the impact of surge events on potential discharges.

The PWV of the bottom ash system was calculated at **711,059** gallons with a surge volume of **274,517** gallons.

Bottom ash purge water from the four approved categories of purge water under 40 CFR § 423.13(k)(2)(i)(A) are relevant to operation and maintenance of the Nelson 6 bottom ash system and indicate a discharge of over 10% of the PWV on a 30-day rolling average basis (see, Table 1). Accordingly, Entergy requests a purge water allowance of 10% of PWV on a 30-day rolling average for the following occurrences. First, when the system modifications to maximize recirculation are implemented, water chemistry challenges can arise requiring total suspended solids (TSS) and pH to be managed with purging to avoid impacts to system operation or maintenance. Second, Nelson 6 is located in Calcasieu Parish, Louisiana, which has above the national average precipitation. Purging storm water will support the system water balance when precipitation-related inflows are generated from storm events exceeding the 10-year storm event of 24-hour or longer duration (e.g., a 50-year, 30-day storm event). Third, the bottom ash system receives inflows (specifically, boiler blowdown) other than bottom ash transport water, which also can result in the need to discharge water from the bottom ash system. Finally, certain major maintenance events can require that the bottom ash system be partially or entirely drained.

**Table 1 - The 30-Day Rolling Average Calculated Discharge Volume as a Percent of PWV**

Type of Discharge Event	Current Operation
Exceeding 10-year, 24-hour (or longer duration) storm event up to a 50-year, 30-day storm event <i>See 40 CFR §423.13(k)(2)(i)(A)(1)</i>	2.4%
Discharge needs to maintain water balance due to wastewater inflows <i>See 40 CFR §423.13(k)(2)(i)(A)(2)</i>	10.6%
Discharge needs to maintain water chemistry <i>See 40 CFR §423.13(k)(2)(i)(A)(3)</i>	5.4%
Other infrequent maintenance events <i>See 40 CFR §423.13(k)(2)(i)(A)(4)</i>	4.7%
Total % of PWV of potential coincident maximum volume discharged per day	23.1%
<b>Estimated Potential Total % of PWV Discharged</b>	23.1%
Operational strategies may be employed to reduce the total 30-day rolling average discharge lower than the sum of the individual contributors. The requested 10% total discharge volume reflects the implementation of these strategies.	

Based upon recent flow data provided by Nelson 6 operations personnel, the facility can operate without exceeding a discharge limitation of 10% of PWV. Entergy installed a flow instrument to facilitate daily flow measurement. With the time for compliance provided by the Agency, Entergy has performed inspections and maintenance on the meter, troubleshooting erroneous values. Entergy believes the procedure and maintenance schedule in place will ensure meter accuracy moving forward. Although Table 1 indicates that Nelson 6 will discharge over 10% of PWV as a 30-day rolling average, based on the recent operating data, it is expected that Nelson 6 will be able to maintain the less than 10% of PWV as a 30-day rolling average beginning January 1<sup>st</sup> 2026 onward.

Section 5 of this evaluation includes a list and narrative description of existing wastewater treatment systems that would receive proposed flows of bottom ash purge water.

## 1. INTRODUCTION AND BACKGROUND

The RS Nelson Generating Station Unit 6 (Nelson 6) is a 580 MW Unit located in Westlake, Louisiana that is fueled by PRB coal. The facility has a bottom ash system that handles bottom ash transport water (BATW). In November 2015 and October 2020, EPA published and then modified the Effluent Limitations Guidelines and Standards (ELGs) for the Steam Electric Power Generating Point Source Category. Under the current ELGs, the technology basis for the best available technology economically achievable (“BAT”) standard for BATW is a high-recycle rate system that recycles most bottom ash transport water. In accordance with the current ELGs, a high-recycle rate system that is subject to the BAT standard may be allowed to discharge a limited amount of bottom ash purge water consistent with 40 CFR 423.13(k)(2)(i), summarized as follows:

- The discharge of pollutants in bottom ash transport water from a properly installed, operated, and maintained bottom ash system is authorized under the following conditions:
  - (1) To maintain system water balance when precipitation-related inflows are generated from storm events exceeding a 10-year storm event of 24-hour or longer duration,
  - (2) To maintain system water balance when regular inflows from wastestreams other than bottom ash transport water exceed the ability of the bottom ash system to accept recycled water and segregating these other wastestreams is not feasible,
  - (3) To maintain system water chemistry where installed equipment at the facility is unable to manage pH, corrosive substances, substances or conditions causing scaling, or fine particulates to below levels which impact system operation or maintenance,
  - (4) To conduct maintenance not otherwise included in the above.
- The total volume of the discharges listed above in no event shall exceed a 30-day rolling average of ten percent of the primary active wetted bottom ash system volume (referred to as the primary wetted volume or “PWV”).

Based upon recent flow data provided by Nelson 6 operations personnel, the facility can operate without exceeding a discharge limitation of a 30-day rolling average of 10% of the PWV .

While certain recent records showed anomalously high discharge values, subsequent investigations by plant personnel determined that the flow instrumentation had been compromised; accordingly, those anomalous readings are not representative of actual discharges.

## 2. SCOPE OF EVALUATION

This initial evaluation provides certain information listed in 40 CFR 423.19(d)(3)(i) through (ix) based on the current operation of the Nelson 6 bottom ash system. The scope of this evaluation includes the following deliverables and assessments based on the Nelson 6 drawings and documents provided by Entergy:

- Calculation of the primary active wetted bottom ash system volume as defined in §423.11(aa).
- Material assumptions, information, and calculations used to determine the primary active wetted bottom ash system volume.
- A list of potential discharges identified under 40 CFR 423.13(k)(2)(i)(A)(1) through (4).
- A narrative description of the wastewater treatment system.

## 3. THE PRIMARY ACTIVE WETTED BOTTOM ASH SYSTEM VOLUME 40 CFR 423.19(d)(3)(iv) and 40 CFR 423.19(d)(3)(v)

S&L developed a primary wetted volume calculation including all bottom ash and ash water handling equipment, piping and trenches based on the drawings provided by Entergy. Per 40 CFR 423.11(aa), the term “primary active wetted bottom ash system volume” is defined as:

...the maximum volumetric capacity of bottom ash transport water in all non-redundant piping (including recirculation piping) and primary bottom ash collection and recirculation loop tanks (e.g., bins, troughs, clarifiers, and hoppers) of a wet bottom ash system, excluding the volumes of surface impoundments, secondary bottom ash system equipment (e.g., installed spares, redundancies, and maintenance tanks), and non-bottom ash systems that may direct process water to the bottom ash.

Per the stated definition, the total calculated primary active wetted bottom ash system volume was determined to be **711,059** gallons. Refer to Appendix A – Bottom Ash Volume Calculation for the calculation details, including material assumptions, information, and calculations used by the certifying professional engineer to determine the primary wetted bottom volume.

The bottom ash system has not been modified since the previous revision of this evaluation in 2021 in a way which alters the PWV calculation in Appendix A.

#### **4. ALL POTENTIAL DISCHARGES 40 CFR 423.19(d)(3)(vi) & 40 CFR 423.19(d)(3)(vii)**

The Nelson 6 bottom ash system is properly installed, operated, and maintained. The system was evaluated for potential discharges listed in 40 CFR 423.13(k)(2)(i)(A)(1)–(4) and the details of the material assumptions and calculations are included within. The following discharges are expected from the system:

- Discharges to Balance Precipitation-related Flows (40 CFR 423.13(k)(2)(i)(A)(1))
  - Rainfall runoff exceeding a 10-year storm event of 24 hour or longer duration collected in the bottom ash system and cannot be managed by installed spares, redundancies, maintenance tanks, and other secondary bottom ash system equipment.
- Discharges to Balance Wastewater Inflows (40 CFR 423.13(k)(2)(i)(A)(2))
  - Boiler Blowdown
- Discharges to Maintain System Water Chemistry (40 CFR 423.13(k)(2)(i)(A)(3))
  - Water discharges to maintain bottom ash system total suspended solids (TSS) to 0.3 wt% or less; and
  - Water discharges to maintain bottom ash system pH.
- Other Discharges related to maintenance not otherwise included (40 CFR 423.13(k)(2)(i)(A)(4))
  - Discharge to drain the system in a timely manner; and
  - Other maintenance events described in Section 4.4 that cannot be managed by installed spares, redundancies, maintenance tanks, and other secondary bottom ash system equipment.

##### **4.1. DISCHARGES TO BALANCE PRECIPITATION-RELATED INFLOWS AS DESCRIBED IN 40 CFR 423.13(k)(2)(i)(A)(1)**

As part of this evaluation, S&L evaluated storms exceeding a 10-year, 24-storm event to determine whether such rainfall events trigger the need to discharge purge water from the bottom ash system. Refer to Appendix B – Bottom Ash System Rainfall Estimation Calculation for the calculation details, including material assumptions, information, and calculations used by the certifying professional engineer to

---


determine the amount of purge water potentially required to maintain the bottom ash system's water balance due to precipitation-related inflows.

This evaluation takes into account projected surge capacity in the system during relevant events. The calculated surge capacity is 274,517 gallons. The equipment included in determination of the surge capacity of the system is identified in Appendix A – Primary Wetted Volume.

During sluicing operations, ash sluiced to the dewatering bin displaces water in the hydrobin. This displaced water passes through the settling tank and is retained in the surge tank. The maximum quantity of sluiced ash is approximately the volume of ash available in the dewatering bin. For this evaluation, it is assumed that the rainfall event occurs during the sluicing operation and the volume of ash collected within the bottom ash system will be subtracted from the available volume in the surge tank.

The calculated surge capacity volumes were plotted along with the upper and lower bounds (as well as the average) of the 90% confidence rainfall volumes from the NOAA Atlas 14 Point Precipitation Frequency Estimates for the Nelson 6 site. Charts address the 10-, 25-, and 50-year storm events with durations from 6-hours to 30-days and include volumes calculated using the areas over which rainwater is expected to drain into the bottom ash system. Additional charts were created to illustrate the expected discharge rates upper bound for each event duration as a percentage of the PWV averaged over a 30-day period. These charts indicate that Nelson 6's surge capacity will be exceeded with precipitation events of sufficient duration, and thus some volume of outflow must be permitted to account for these events.


**Figure 1 - 10-Year Rainfall Summary**



The Nelson 6 bottom ash system can manage the average 10-year, 24-hour rainfall event without purge water because system surge capacity is sufficient to contain the average level 10-year, 24-hour rainfall event (even at the 90% confidence interval).

In the event of a 10-year, 30-day rainfall event, however, the high of the 90% confidence interval exceeds Unit 6 system surge capacity by up to 10,272 gallons per day, or 1.4% of the PWV averaged over a 30-day period, and therefore may require a purge water discharge.


**Figure 2 - 25-year Rainfall Summary**



Charts for the 25-year rainfall events are similar to those of the 10-year rainfall events shown in Figure 1, only the magnitude of these events are greater, and thus the unit's surge capacity is overwhelmed within a shorter period of time. Within this 25-year dataset, a 30-day rainfall event could require an average daily

purge water discharge of 14,209 gallons, or 2.0% of PWV, per day (i.e., 30-day rolling average) for Unit 6 to manage the influx of rainwater.

**Figure 3 - 50-Year Rainfall Summary**



The worst-case rainfall events included in this evaluation were the 50-year storms. Within this 50-year dataset, a 30-day rainfall event could be expected to require an average daily purge water discharge of 17,197 gallons, or 2.4% of PWV, per day (i.e., 30-day rolling average) for Unit 6 to manage the influx of rainwater.

---

4.2. DISCHARGES TO BALANCE WASTEWATER INFLOWS AS DESCRIBED IN 40 CFR 423.13(k)(2)(i)(A)(2)

4.2.1. Boiler Blowdown

The only current wastewater inflow to the bottom ash system, other than BATW, is boiler blowdown. Boiler blowdown is necessary to control boiler water chemistry and prevent corrosion of wetted boiler surfaces and substandard steam quality. Blowdown at Nelson 6 is delivered to the blowdown flash tank at grade in the boiler area. In the blowdown flash tank, part of the energetic blowdown flashes to steam and the remainder drops in temperature to boiling, or saturation, temperature. This blowdown flows by gravity to the Boiler Ash Hopper Sump, where it enters the bottom ash system. The estimated 30-day average flow of bottom ash purge water required to balance potential boiler blowdown input is provided in Table 2.

Refer to Appendix D – Water Balance for the calculation details, including material assumptions, information, and calculations used by the certifying professional engineer to determine the amount of purge water potentially required to maintain the bottom ash system's water balance due to inflow of boiler blowdown.

**Table 2 - Estimated 30-day Average Flow of Bottom Ash Purge Water Required to Balance Potential Boiler Blowdown Input**

<b>30-days of Potential Boiler Blowdown (Gallons)</b>	<b>Total Potential Discharge After Accounting for Water in Ash to Landfill, Evaporation, and Surge Capacity (Gallons)</b>	<b>Average Potential Daily Discharge (Gallons per day)</b>	<b>Bottom Ash Purge Flow Required (%PWV/day)</b>
3,278,632	2,254,819	75,161	10.6%

4.3. DISCHARGES TO MAINTAIN SYSTEM WATER CHEMISTRY AS DESCRIBED IN 40 CFR 423.13(k)(2)(i)(A)(3)

The EPA studied the behavior of coal ash particles in water (“Behavior of Coal Ash Particles in Water: Trace Metal Leaching and Ash Settling”, EPA-600/7-80-067, March 1980). The report addressed the following six major areas of concern in wet ash disposal: (1) characteristics of ashes and ash pond effluents; (2) effects of ash and raw water characteristics on the pH of ash pond water; (3) methods for pH adjustment of ash pond effluents; (4) settling characteristics of both fly ash and bottom ash; (5) leaching of minerals

from ashes; and (6) relationship of trace metals to pH and concentration of suspended solids in ash pond effluents. Of specific interest to Nelson 6 are the evaluations of ash pond water quality characteristics in relation to the chemical quality of the fuel burned at 12 TVA coal-fired power stations.

The primary system chemistry concern is the buildup of bottom ash fines in the recirculating transport water. Particles smaller in diameter than 75  $\mu\text{m}$  are considered fines. Fines enter the bottom ash system with other, larger, particles of ash falling into the hopper and occasionally from fracturing of the larger particles of ash due to the thermal shock of entering the hopper water. The ash in the dewatering bin system removes particles above 300  $\mu\text{m}$  in size based on input from a reputable dewatering bin manufacturer. A small percentage of fines (e.g., <5.0%) will exit the bottom ash system through entrainment in bottom ash purge water and ash in trucks being taken to landfill. The remaining fines will concentrate in the bottom ash water until the mass flow rate of fines into the system is equal to that exiting. In order to mitigate equipment and piping erosion and reduce maintenance impacts due to the concentration of fines within the bottom ash system, the system needs an amount of purge to maintain a concentration of 0.3% or 3000 mg/L. The estimated 30-day average flow of bottom ash purge required to mitigate for fines within the bottom ash system is provided in Table 3. Refer to Appendix C – Bottom Ash Purge Water Suspended Solids Estimate for the calculation details, including material assumptions, information, and calculations used by the certifying professional engineer to determine the amount of purge water required to maintain a fines concentration of 0.3%.

**Table 3 - Estimated 30-day Average Flow of Bottom Ash Purge Water Required**

<b>Bottom Ash System</b>	<b>Bottom Ash Purge Flow Required (%PWV/day)</b>
Unit 6	5.4%

Another system chemistry concern is the scaling or corrosivity of the BATW in high-recycle bottom ash systems. To estimate the pH of the high-recycle bottom ash system, S&L used the chart on EPA-600/7-80-067, pg. 17 and the Nelson 6 fuel ash quality from five fuel sources used at Nelson 6. The chart relates the ratio of ash calcium oxide and magnesium oxide concentrations to the ash sulfur trioxide concentration. Results of applying the EPA analysis to Nelson 6 are shown in Table 4.

**Table 4 – Estimate of Bottom Ash System Equilibrium pH at Nelson 6**

Nelson 6 Fuel Source	Fuel Ash Calcium Oxide (%)	Fuel Ash Magnesium Oxide (%)	Fuel Ash Sulfur Tri-Oxide (%)	Ratio of (CaO+MgO) to SO <sub>3</sub>	Estimated pH
Belle Ayre Mine	26.14	5.22	10.99	2.85	~3 (acidic)
Black Thunder	20.11	4.10	8.42	2.87	~3 (acidic)
Coal Creek	19.78	3.46	9.07	2.56	~3 (acidic)
Peabody NARM 2018	23.9	6.2	10.0	3.01	~3 (acidic)
Peabody NARM 2019	24.1	6.2	10.0	3.03	~3 (acidic)

Each fuel chemistry indicates that, at equilibrium, the ash will create an acidic water chemistry. The predicted acidic chemistry of the bottom ash system will occur at system chemical equilibrium, which takes time to achieve. In order to prevent the system from reaching chemical equilibrium, the water in the system should be continuously discharged and made-up with fresh utility, service water, or rainfall collected in the system. The purge water rate for TSS discussed above will also provide more protection from constituents in the ash creating acidic water in the system than purging at a lower rate.

**4.4. OTHER DISCHARGES REQUIRED TO CONDUCT MAINTENANCE NOT OTHERWISE INCLUDED AS DESCRIBED IN 40 CFR 423.13(k)(2)(i)(A)(4)**

Complete drains of the bottom ash system may be periodically necessary to conduct inspections and maintenance during outages that cannot be performed while the plant is operating. In order to drain the entire bottom ash system for maintenance and maintain the 30-day rolling average per day discharge requirement, the allowable discharge must be equal to or greater than the following:

$$\frac{\%PWV}{day} = \frac{(TSV/PWV)}{30\ days}$$

Where:

TSV: Total System Volume

PWV: Primary Wetted Volume

%PWV/day: Minimum Percentage of Primary Wetted Volume per Day (rounded up)

For example, the Nelson 6 bottom ash system has a total system volume of 985,576 gallons and a PWV of 711,059 gallons. In order to drain the system completely for a maintenance event, the %PWV/day must be greater than:

$$\frac{\%PWV}{day} = \frac{(985,576/711,059)}{30 \text{ days}} = \frac{4.7\%PWV}{day}$$

There are several infrequent maintenance events which require draining the portions of the bottom ash system but fall short of complete discharge. Examples of such events are the following:

- Temporary drainage of individual system tanks and hoppers are likely during replacement/repair of system components, including:
  - Dewatering bin – Discharge gate, center baffle, dewatering units, etc.
  - Bottom ash hopper – refractory lining, crushers, hopper sluice gates, jetting nozzles, etc.
- Temporary drainage of the bottom ash hopper due to large clinkers of bottom ash blocking the discharge that cannot be rodded out while the unit is online.
- System cleaning / inspection during outages, including:
  - Dewatering bin / settling / surge tanks;
  - Bottom ash hopper and seal trough; and
  - Pyrite tanks.

These events require the bottom ash system to discharge less volume; therefore, the calculated volume discharge to drain the entire system will be sufficient for each of the maintenance events listed above.

#### 4.5. TOTAL DISCHARGE SUMMARY - 40 CFR 423.19(d)(3)(vi) & 40 CFR 423.19(d)(3)(vii)

Table 1 at the beginning of this report summarizes each of the designated categories of discharge water from the bottom ash system as defined by 40 CFR 423.13(k)(2)(i)(A)(1) through (4). In some instances, the causes and the timing of these discharge events and scenarios are independent of each other. However, events can influence one another and affect the total percent discharged (e.g., rain influencing water chemistry). It is possible that operational considerations can further minimize the risk that the percent discharges associated with each scenario would function in a purely additive manner. For example, in anticipation of a maintenance event, the purge to balance water chemistry could be minimized before and after, as needed.

Discharge volumes summarized in Table 1 indicate that Nelson 6 would require 23.1% of PWV based on the potential coincident maximum volume discharged per day. Based upon flow data from May 1, 2023 through November 11, 2025 provided by Nelson 6 operations personnel, the facility has demonstrated the ability to operate without exceeding a discharge limitation of 10% of PWV. Entergy installed a flow instrument to facilitate daily flow measurement. With the time for compliance provided by the Agency, Entergy has performed inspections and maintenance on the meter, troubleshooting erroneous values. Entergy believes the procedure and maintenance schedule in place will ensure meter accuracy moving forward.

Although Table 1 indicates that Nelson 6 will discharge over 10% of PWV as a 30-day rolling average, based on the recent operating data, it is expected that Nelson 6 will be able to maintain the less than 10% of PWV as a 30-day rolling average beginning January 1<sup>st</sup> 2026 onward. Accordingly, the requested purge water allowance is 10% PWV on a 30-day rolling average.

## **5. NARRATIVE DESCRIPTION OF THE WASTEWATER TREATMENT SYSTEM 40 CFR 423.19(d)(3)(viii) & 40 CFR 423.19(d)(3)(ix)**

Below is a list of the wastewater treatment systems Nelson Unit 6 is equipped with which do not treat BATW:

- Nelson Plant Sewage Treatment
- Metal Cleaning Waste Lagoon
- Ash Disposal Area Sewage Treatment

Nelson Unit 6 is equipped with the following wastewater treatment system which does treat BATW:

- Settling Pond

Discharged BATW at Nelson is routed to the settling pond, located to the west of Nelson 6, for additional treatment prior to being discharged via Outfall 003. The settling pond is an 11.6-acre pond consisting of three areas in a series (a grit chamber, a sediment retention chamber, and a final settling chamber) that is intended to ensure that the blend of the following current and future wastewater streams meet the discharge limitations in Nelson Station's NPDES permit:

- Bottom Ash Transport Water and Bottom Ash Purge Water
- Floor Drainage Storm Water from Oil/Water Separator

- Coal Pile Runoff
- Coal Ash Disposal Landfill Runoff
- Coal Handling Area Runoff
- Optional Routing of Cooling Tower Blowdown and Drift
- Combustion Residual Leachate
- Water associated with demolition activities
- Low volume wastewaters
- Miscellaneous non-process wastewaters including but not limited to washdown water, water used for dust suppression, and line flushing
- Previously monitored hydrostatic test water

The grit chamber is concrete-lined and is designed to retain large, fast-settling solids. It is designed to facilitate easy sediment removal by mechanical means (backhoe or dragline) without taking the pond out of service. The sediment retention chamber is designed to collect the majority of the settled solids contained in the water leaving the grit chamber. This chamber is also designed to facilitate easy sediment removal by bulldozer or front-end loader, as it requires periodic cleaning. The largest portion of the Settling Pond is the final settling chamber. The final settling chamber reduces the wastewater flow to its lowest velocity, allowing fine particles to settle out of the water prior to discharge via Outfall 003.

Given that the present overflow from the bottom ash system is routed to the Settling Pond, the system flow path is not expected to change due to future discharge of bottom ash purge water and compliance with the ELGs.

---

## APPENDIX A – WETTED BOTTOM ASH VOLUME CALCULATION

**ENTERGY LOUISIANA, LLC**

**NELSON 6**

**DOCUMENT NO. 2021-03195**  
**WETTED BOTTOM ASH VOLUME**  
**CALCULATION**

**Rev. 0**  
**October 27, 2021**



## WETTED BOTTOM ASH VOLUME CALCULATION

### TABLE OF CONTENTS

Section	Title	Page No.
1	<b>PURPOSE AND SCOPE:</b>	4
2	<b>DESIGN INPUT:</b>	4
3	<b>ASSUMPTIONS:</b>	4
4	<b>METHODOLOGY &amp; ACCEPTANCE CRITERIA:</b>	5
5	<b>CALCULATIONS:</b>	5
6	<b>RESULTS:</b>	6
7	<b>REFERENCES:</b>	6
8	<b>ATTACHMENTS:</b>	6

	A	B	C	D	E	F	G	H
1			ENTERGY LOUISIANA, LLC NELSON 6 DOCUMENT NO. 2021-03195				PROJECT NO. 13603-006 Date: 27 October 2021	
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
32								
33								
34								
35								
36								
37								
38								
39								
40								
41								
42								
43								
44								
45								
46								
47								
48								
49								
50								
51								
52								
53								
54								
55								
56								
57								
58								
59								
60								
61								
62								
63								
64								

A	B	C	D	E	F	G	H
1		ENTERGY LOUISIANA, LLC NELSON 6 DOCUMENT NO. 2021-03195				PROJECT NO. 13603-006 Date: 27 October 2021	
2							
3							
4							
65	7.04	Area of a Tapered Rectangular Hopper Formula: <a href="https://www.easycalculation.com/measurement/volume-of-rectangular-hopper.php">https://www.easycalculation.com/measurement/volume-of-rectangular-hopper.php</a>					
66							
67							
68	8.00	ATTACHMENTS: Drawings in attachments 8.02 through 8.13 have been omitted from the LDEQ submittal package due to confidentiality limitations.					
69	8.01	Wetted Ash Volume Calculation Summary					
70	8.02	Pyrites and Pyrites Transfer Tank Drawings					
71	8.03	Bottom Ash Hopper and Seal Trough Drawings					
72	8.04	Dewatering Bins Drawing					
73	8.05	Settling Tank Drawing					
74	8.06	Surge Tank Drawing					
75	8.07	Bottom Ash Hopper Sump Drawing					
76	8.08	Loadout Sump Drawing					
77	8.09	Boiler Area Trenches Drawing					
78	8.10	Ash Handling Area Trenches Drawing					
79	8.11	Piping Isometrics					
80	8.12	Piping Specification CL 125					
81	8.13	Bottom Ash System PFD and P&IDs					
82							

ENTERGY LOUISIANA, LLC  
NELSON 6  
DOCUMENT NO. 2021-03195



PROJECT NO. 13603-006  
Date: 27 October 2021

**ATTACHMENT 8.01**  
**WETTED ASH VOLUME CALCULATION SUMMARY**

WETTED ASH VOLUME SUMMARY - EQUIPMENT

Equipment	Volume (ft <sup>3</sup> )	Wetted Qty	Spare Qty	Wetted Volume (gal)	Surge Capacity Volume (ft <sup>3</sup> )	Surge Capacity (gal) - not part of wetted volume	Notes
Pyrites Hoppers (x3)	36	3	3	817	36	817	Wetted volume: x3 hoppers Surge capacity: x3 hoppers
Pyrites Transfer Tank	750	1	-	5,611	181	1,354	Surge capacity is additional 1.6ft
Ash Hopper (both)	7,702	2	-	115,222	386	2,887	Wetted volume is normal water level. Surge capacity assumed to be 6" to emergency overflow level from normal water level.
Seal Trough	438	1	-	3,276	-	-	
Dewatering Bins (x1)	23,497	1	1	175,758	23,497	175,758	Wetted volume: x1 bin Surge capacity: x1 bin
Settling Tank	18,901	1	-	141,379	-	-	
Surge Tank	26,607	1	-	199,020	11,781	88,122	Wetted volume: 6ft from overflow. Surge volume: top 6ft of tank up to overflow.
Bottom Ash Hopper Sump	4,177	1	-	31,244	261	1,952	Wetted volume: 2ft from top. Surge volume: up to overflow.
Loadout Sump	2,150	1	-	16,082	-	0	Wetted volume: 2ft from top. Surge volume: up to overflow.
Trenches							
Boiler Area	1,074	1	-	8,034	-	-	Assumed 1.0ft working water level for wetted volume.
DW Bins Area	175	1	-	1,309	-	-	Assumed 0.5ft working water level. Excludes DW bins branch.
<b>Ash Water Volume in Equipment and Trenches</b>	<b>85,508</b>			<b>697,752</b>			
<b>Ash Water Surge Capacity</b>						<b>270,890</b>	

WETTED ASH VOLUME CALCULATION - PIPING

Piping	Wetted Volume (ft <sup>3</sup> )	Wetted Volume (gal)	Surge Volume (ft <sup>3</sup> )	Surge Volume (gal)	Notes
01 Surge Tank to Recirc Pumps (6-M-8JR-129)	163	1,218			
02 Recirc Pumps Discharge to Boiler Area (6-M-8JR-132_1)	149	1,117			
03 Recirc Pumps Discharge to Boiler Area (6-M-8JR-132_2)	180	1,347			
04 Recirc Pumps Discharge to Boiler Area (6-M-8JR-132_3)	140	1,047			
05 Recirc. Pump Discharge Header to Pyrites Transfer Tank (6-M-8JM-305)	2	15			
06 Header to Bottom Ash Hopper (6-M-8JR-3107)	7	52			
07 Ash Hopper Booster Pumps To Bottom Ash Hoppers Sheet 1_6-M-8JR-380	39	292			
08 Ash Hopper Booster Pumps To Bottom Ash Hoppers Sheet 2_6-M-8JR-380	7	49			
09 Seal Trough Supply_6-M-8JR-389	46	346			
10 Wall Cooling Supply Sheet 1_6-M-8JM-384	30	224			
11 Wall Cooling Supply Sheet 1_6-M-8JM-384	21	159			
12 Wall Cooling Supply Sheet 1_6-M-8JM-384	27	199			
13 Bottom Ash Piping Pumps to Dewatering Bins_06-1240C	267	1,999			
14 Bottom Ash Sump to Dewatering Bins_6-M-8JR-3132	57	426			
15 Boiler Area Sump Pump Disch. To Dewatering Bins_6-M-8JR-101	139	1,040			
16 Dewatering Bin Overflow Header to Settling Tank_6-M-8JR-118	43	322			
17_Ash Loadout Area Sump Pumps to Dewatering Bins 6A & 6B_6-M-8JR-102	47	349			
18 Recirc. Pump Discharge Hdr. to pyrites hoppers_6-M-8JM-306	47	348			
19 Dewatering Bin 6A to ash loadout area sump header_6-M-8JR-106	33	249	33	249	
20 Dewatering Bin 6A to Overflow Header_6-M-8JR-103	22	162	22	162	
21 From Recirc. Pump Disch. Header to Bottom Ash Pumps Disch. Hdr_6-M-8JM-3127	7	53			
22 Recirculation Pump Discharge Header to Ash Loadout Area Sump_6-M-8JR-155	15	114			
23 Seal Trough Drains_6-M-8JM-392	24	178			
24 Suction Make up at bottom ash hopper Sheet 2_6-M-8JM-376	119	886			
25 Suction Make up at bottom ash hopper Sheet 2_6-M-8JM-376	37	274			
26 Wall Cooling Spray Drains_6-M-8JM-391	28	208			
Misc. Secondary Piping	85	634			5% of sum of major process piping listed
<b>Ash Water Volume in Piping</b>	<b>1,779</b>	<b>13,307</b>	<b>55</b>	<b>411</b>	

ENTERGY LOUISIANA, LLC  
NELSON 6  
DOCUMENT NO. 2021-03195



PROJECT NO. 13603-006  
Date: 27 October 2021

**ATTACHMENT 8.02**  
**PYRITES AND PYRITES TRANSFER TANK DRAWINGS**

ENTERGY LOUISIANA, LLC  
NELSON 6  
DOCUMENT NO. 2021-03195



PROJECT NO. 13603-006  
Date: 27 October 2021

**ATTACHMENT 8.03**  
**BOTTOM ASH HOPPER AND SEAL TROUGH DRAWINGS**

ENTERGY LOUISIANA, LLC  
NELSON 6  
DOCUMENT NO. 2021-03195



PROJECT NO. 13603-006  
Date: 27 October 2021

**ATTACHMENT 8.04  
DEWATERING BINS DRAWING**

ENTERGY LOUISIANA, LLC  
NELSON 6  
DOCUMENT NO. 2021-03195



PROJECT NO. 13603-006  
Date: 27 October 2021

**ATTACHMENT 8.05  
SETTLING TANK DRAWING**

ENTERGY LOUISIANA, LLC  
NELSON 6  
DOCUMENT NO. 2021-03195



PROJECT NO. 13603-006  
Date: 27 October 2021

**ATTACHMENT 8.06  
SURGE TANK DRAWING**

ENTERGY LOUISIANA, LLC  
NELSON 6  
DOCUMENT NO. 2021-03195



PROJECT NO. 13603-006  
Date: 27 October 2021

**ATTACHMENT 8.07**  
**BOTTOM ASH HOPPER SUMP DRAWING**

ENTERGY LOUISIANA, LLC  
NELSON 6  
DOCUMENT NO. 2021-03195



PROJECT NO. 13603-006  
Date: 27 October 2021

**ATTACHMENT 8.08  
LOADOUT SUMP DRAWING**

ENTERGY LOUISIANA, LLC  
NELSON 6  
DOCUMENT NO. 2021-03195



PROJECT NO. 13603-006  
Date: 27 October 2021

**ATTACHMENT 8.09  
BOILER AREA TRENCHES DRAWING**

ENTERGY LOUISIANA, LLC  
NELSON 6  
DOCUMENT NO. 2021-03195



PROJECT NO. 13603-006  
Date: 27 October 2021

**ATTACHMENT 8.10**  
**ASH HANDLING AREA TRENCHES DRAWING**

ENTERGY LOUISIANA, LLC  
NELSON 6  
DOCUMENT NO. 2021-03195



PROJECT NO. 13603-006  
Date: 27 October 2021

**ATTACHMENT 8.11  
PIPING ISOMETRICS**

ENTERGY LOUISIANA, LLC  
NELSON 6  
DOCUMENT NO. 2021-03195



PROJECT NO. 13603-006  
Date: 27 October 2021

**ATTACHMENT 8.12  
PIPING SPECIFICATION CL 125**

ENTERGY LOUISIANA, LLC  
NELSON 6  
DOCUMENT NO. 2021-03195



PROJECT NO. 13603-006  
Date: 27 October 2021

**ATTACHMENT 8.13  
BOTTOM ASH SYSTEM PFD AND P&IDS**

---

Entergy  
RS Nelson Unit 6  
Project Number A13603.006  
Bottom Ash System Evaluation



SL Report No.: SL-016282  
Revision 1, For Information  
December 22, 2025

---

## **APPENDIX B – BOTTOM ASH SYSTEM RAINFALL ESTIMATION CALCULATION**

**Entergy Louisiana, LLC**

**Nelson Power Plant Unit 6**

**DOCUMENT NO. 2021-03526**  
**BOTTOM ASH SYSTEM RAINFALL**  
**EVALUATION**

**Rev. F**  
**October 27, 2021**



## ***Table of Contents***

Total Pages: 7

### ***Contents***

1. PURPOSE AND SCOPE .....	3
2. DESIGN INPUT .....	3
2.1 <i>Rainfall Data</i> .....	3
2.2 <i>Drainage Areas</i> .....	3
2.3 <i>Runoff Coefficient</i> .....	4
3. ASSUMPTIONS .....	4
4. METHODOLOGY AND ACCEPTANCE CRITERIA .....	4
4.1 <i>Methology</i> .....	4
4.2 <i>Acceptance Criteria</i> .....	4
5. CALCULATION .....	4
5.1.1 <i>Area 1 Runoff Volume</i> .....	5
5.1.2 <i>Area 2 Runoff Volume</i> .....	5
5.1.3 <i>Area 3 Runoff Volume</i> .....	5
6. CONCLUSION.....	6
6.1 <i>10 Year-24 Hour Storm Event</i> .....	6
6.2 <i>Other Storm Events</i> .....	7
7. REFERENCES.....	7
8. ATTACHMENTS.....	7

## 1. PURPOSE AND SCOPE

The EPA published a new revision of the 40 CFR 423 Effluent Limitations Guidelines (ELG) on December 31, 2020. The revision allows for discharge of stormwater from the bottom ash system under certain circumstances. The purpose of this calculation is to determine rainfall/stormwater contribution into the bottom ash system through direct rainfall into uncovered equipment or onto surfaces that drain into the bottom ash system for Entergy Louisiana, LLC's Nelson Power Plant Unit 6 in Westlake, Louisiana. This information will be used to assess, in a separate calculation, the potential amount of purge water discharge in specified storm events.

## 2. DESIGN INPUT

### 2.1 Rainfall Data

As stated in 40 CFR 423 (Reference 7.1), discharges of bottom ash transport water may be authorized to maintain system water balance when precipitation-related inflows are generated from storm events exceeding a 10-year storm event of 24-hour or longer duration. Because within the preamble of the rule it specifies the 100-year event and longer does not need to be considered, this document analyzes 10-, 25-, and 50-year events, and calculates anticipated discharges. The duration presented within the Bottom Ash System Rainfall Calculation was the 24-hour event, but all durations from 6 hours to 30 days were analyzed and included in Attachments 8.3 through 8.5. The rainfall depths used were the high, low, and average depths as published by NOAA in Attachment 1. The high and low depth are estimates as the upper and lower bounds, respectively, of the 90% confidence interval. The probability that the rainfall depths will be greater than the upper bound or less than the lower bound is 5 percent, as stated by NOAA in note 1 on Attachment 8.1.

Within this calculation, the 10-year, 24-hour depth will be utilized as the rainfall depth in order to outline the process used to calculate each additional storm event. For Unit 6 at the Nelson Power Plant, the average 10-year, 24-hour rainfall depth value is 8.21 inches per NOAA Atlas 14 (Reference 7.2). The rainfall depth for the lower and upper boundaries of the 90% confidence interval for the 10-year, 24-hour storm is 6.7 inches and 10.1 inches, respectively. Rainfall depths from NOAA Atlas 14 are included as Attachment 8.1.

### 2.2 Drainage Areas

There are three separate drainage areas that contribute to the bottom ash system that have been considered for rainfall impact, as follows:

Area 1 is the Settling and Surge tanks, as well as the paved, at-grade runoff surrounding those tanks that is discharged into the bottom ash system.

Area 2 is both of the Dewatering Bins.

Area 3 is the stormwater runoff from the Boiler Building mat foundation that is discharged into the bottom ash system.

Each of these areas can be seen outlined and quantified on Attachment 8.2, which are applicable Nelson Power Plant drawings that were used to obtain the runoff areas. The drawings have been omitted from the LDEQ submittal package due to confidentiality limitations.

### **2.3 Runoff Coefficient**

The runoff coefficient was calculated as 1.0 for all the areas. These values can be considered conservative values as taken from the Louisiana DOT Hydraulics Manual as shown in Reference 7.3.

## **3. ASSUMPTIONS**

No assumptions were used in this calculation.

## **4. METHODOLOGY AND ACCEPTANCE CRITERIA**

### **4.1 Methodology**

Utilizing the existing Plant drawings as shown in Attachment 8.2, three areas were found that contributed to the bottom ash system. Area 1 is considered the Settling and Surge tanks, as well as the runoff surrounding those tanks, Area 2 is both Dewatering Bins, and Area 3 is the runoff from the Boiler Building.

Once the contributing equipment and contributing drainage area of the Plant were understood, the area was calculated as shown in Section 2.2 and Attachment 8.2. At this point the runoff volume could be calculated using the 10-year, 24-hour rainfall depth, as shown in Attachment 8.1, and the selected runoff coefficient per Reference 7.3.

The runoff coefficients for each of the areas were selected based on the surfacing and permeability. Because all of these areas are within a heavy industrial area, the runoff coefficients selected was 1.0.

### **4.2 Acceptance Criteria**

No acceptance criteria were applicable for this calculation.

## **5. CALCULATION**

The equation utilized to calculate the runoff volume from each area is shown below. Design inputs for this section are from Section 2.

$$\text{Runoff Volume} = C * d * A$$

Where:

C= Runoff Coefficient (Reference 7.3)

d= Average 10-Year, 24-Hour storm depth as shown on Attachment 8.1 and listed above in Section 2.0

A= Area for each section as shown on Attachment 8.2

#### 5.1.1 Area 1 Runoff Volume

Area 1 consists of the subareas as shown on Attachment 8.2: the Settling Tank, the Surge Tank and the runoff from the area surrounding those two tanks. The runoff volume below is calculated in square feet and converted into gallons.

$$\text{Runoff Volume} = C * d * A$$

$$\text{Runoff Volume} = 1.0 * 8.21 \text{ in} * \frac{1 \text{ ft}}{12 \text{ in}} * (7,958.65 \text{ ft}^2 + 1,592.64 \text{ ft}^2 + 1,965.95 \text{ ft}^2)$$

$$\text{Runoff Volume} = 1.0 * 0.6841 \text{ ft} * 11,517.24 \text{ ft}^2$$

$$\text{Runoff Volume} = 7879.71 \text{ ft}^3 * \frac{7.48 \text{ gallons}}{1 \text{ ft}^3}$$

$$\text{Runoff Volume} = 58,940 \text{ gallons}$$

#### 5.1.2 Area 2 Runoff Volume

Area 2 consists of both of the Dewatering Bins as shown on Attachment 8.2. The runoff volume below is calculated in square feet and converted into gallons.

$$\text{Runoff Volume} = C * d * A$$

$$\text{Runoff Volume} = 1.0 * 8.21 \text{ in} * \frac{1 \text{ ft}}{12 \text{ in}} * (1,206.53 \text{ ft}^2 + 1,206.53 \text{ ft}^2)$$

$$\text{Runoff Volume} = 1.0 * 0.6841 \text{ ft} * 2,413.06 \text{ ft}^2$$

$$\text{Runoff Volume} = 1,650.94 \text{ ft}^3 * \frac{7.48 \text{ gallons}}{1 \text{ ft}^3}$$

$$\text{Runoff Volume} = 12,349 \text{ gallons}$$

#### 5.1.3 Area 3 Runoff Volume

Area 3 consists of the runoff from the boiler building as shown on Attachment 8.2. The runoff volume below is calculated in square feet and converted into gallons.

$$\text{Runoff Volume} = C * d * A$$

$$\text{Runoff Volume} = 1.0 * 8.21 \text{ in} * \frac{1 \text{ ft}}{12 \text{ in}} * 28,176.70 \text{ ft}^2$$

$$\text{Runoff Volume} = 1.0 * 0.6841 \text{ ft} * 28,176.70 \text{ ft}^2$$

$$\text{Runoff Volume} = 18,583.39 \text{ ft}^3 * \frac{7.48 \text{ gallons}}{1 \text{ ft}^3}$$

$$\text{Runoff Volume} = 144,196 \text{ gallons}$$

## 6. CONCLUSION

The runoff volumes for each of the storm events are shown below.

### 6.1 10 Year-24 Hour Storm Event

The 10-year, 24-hour rainfall runoff volumes for each of the three areas are stated below. The values listed are calculated using the average and upper bounds of the 90% confidence interval for the 10-year, 24-hour storm. Because we have considered a 24-hour storm event, we reported the volumes as MGD, as well.

For Area 1, which is comprised of the Settling and the Surge Tank, as well as the surrounding area, the runoff volume for the average rainfall depth is 58,940 gallons or 0.059 MGD. The runoff volume for the upper bounds of the rainfall depth is 72,509 gallons or 0.073 MGD.

For Area 2, which is comprised of both Dewatering Bins, the runoff volume for the average rainfall depth is 12,349 gallons or 0.012 MGD. The runoff volume for the upper bounds of the rainfall depth is 15,192 gallons or 0.015 MGD.

For Area 3, which is comprised of the runoff from the Boiler Building, the runoff volume for the average rainfall depth is 144,196 gallons or 0.144 MGD. The runoff volume for the upper bounds of the rainfall depth is 177,391 gallons or 0.177 MGD.

The total runoff volume for the 10-Year, 24-Hour event from all three of the areas for the average rainfall depth is 215,485 gallons or 0.215 MGD, while the total runoff for the upper bounds of the 10-year, 24-hour event is 265,092 gallons or 0.265 MGD.

## **6.2 Other Storm Events**

As stated above, the volumes calculated were for the 10-Year, 24-hour storm event. The same process shown within the calculation was used to calculate various durations ranging from 6 hours to 30 days for the 10-, 25- and 50-year storm events. A table outlining these volumes for 10-, 25- and 50-year storm events can be found in Attachments 8.3 through 8.5. Graphs outlining volumes for the high, low, and average depths for each of the storm durations are shown in Attachment 8.6 through 8.8 for the 10-, 25- and 50-year storm events, respectively.

## **7. REFERENCES**

- 7.1 "Electronic Code of Federal Regulations." Electronic Code of Federal Regulations (ECFR), EPA, 2020.
- 7.2 US Department of Commerce, National Oceanic and Atmospheric Administration, National Weather Service. "NOAA's National Weather Service." PF Data Server Home - HDSC/OHD/NWS/NOAA, US Department of Commerce, National Oceanic and Atmospheric Administration, National Weather Service.
- 7.3 Hydraulics Manual. State of Louisiana Department of Transportation, 2011.

## **8. ATTACHMENTS**

- 8.1 NOAA Atlas 14
- 8.2 Existing Nelson Plant Drawings- Drawings have been omitted from LDEQ submittal package due to confidentiality limitations (Drawing Numbers: 523-05584-09, 6-C-440-C01, A-C-770-C01)
- 8.3 Rainfall Volumes for 10-Year Storm Events
- 8.4 Rainfall Volumes for 25-Year Storm Events
- 8.5 Rainfall Volumes for 50-Year Storm Events
- 8.6 Graphs of the Rainfall Volumes for the 10-Year Storm Events
- 8.7 Graphs of the Rainfall Volumes for the 25-Year Storm Events
- 8.8 Graphs of the Rainfall Volumes for the 50-Year Storm Events



**NOAA Atlas 14, Volume 9, Version 2**  
**Latitude: 30.2721°, Longitude: -93.2982°**  
**Elevation: 15.2 ft\*\***  
 \* source: ESRI Maps  
 \*\* source: USGS



### POINT PRECIPITATION FREQUENCY ESTIMATES

Sanja Perica, Deborah Martin, Sandra Pavlovic, Ishani Roy, Michael St. Laurent, Carl Trypaluk, Dale Unruh, Michael Yekta, Geoffrey Bonnin

NOAA, National Weather Service, Silver Spring, Maryland

[PF\\_tabular](#) | [PF\\_graphical](#) | [Maps & aerials](#)

### PF tabular

Duration	Average recurrence interval (years)									
	1	2	5	10	25	50	100	200	500	1000
<b>5-min</b>	<b>0.564</b> (0.454-0.712)	<b>0.645</b> (0.519-0.815)	<b>0.777</b> (0.623-0.985)	<b>0.886</b> (0.706-1.13)	<b>1.03</b> (0.796-1.36)	<b>1.15</b> (0.864-1.53)	<b>1.26</b> (0.918-1.72)	<b>1.37</b> (0.961-1.93)	<b>1.52</b> (1.02-2.20)	<b>1.63</b> (1.07-2.41)
<b>10-min</b>	<b>0.826</b> (0.665-1.04)	<b>0.945</b> (0.760-1.19)	<b>1.14</b> (0.912-1.44)	<b>1.30</b> (1.03-1.65)	<b>1.51</b> (1.17-1.98)	<b>1.68</b> (1.27-2.24)	<b>1.84</b> (1.34-2.52)	<b>2.01</b> (1.41-2.83)	<b>2.22</b> (1.50-3.23)	<b>2.38</b> (1.57-3.53)
<b>15-min</b>	<b>1.01</b> (0.811-1.27)	<b>1.15</b> (0.927-1.46)	<b>1.39</b> (1.11-1.76)	<b>1.58</b> (1.26-2.01)	<b>1.85</b> (1.42-2.42)	<b>2.05</b> (1.54-2.73)	<b>2.25</b> (1.64-3.08)	<b>2.45</b> (1.72-3.45)	<b>2.71</b> (1.83-3.94)	<b>2.91</b> (1.92-4.31)
<b>30-min</b>	<b>1.47</b> (1.18-1.85)	<b>1.69</b> (1.36-2.13)	<b>2.05</b> (1.65-2.60)	<b>2.35</b> (1.88-2.99)	<b>2.76</b> (2.12-3.61)	<b>3.06</b> (2.31-4.08)	<b>3.37</b> (2.46-4.61)	<b>3.67</b> (2.57-5.17)	<b>4.07</b> (2.74-5.90)	<b>4.36</b> (2.87-6.46)
<b>60-min</b>	<b>1.95</b> (1.57-2.46)	<b>2.24</b> (1.80-2.83)	<b>2.74</b> (2.19-3.47)	<b>3.17</b> (2.53-4.03)	<b>3.80</b> (2.94-5.03)	<b>4.30</b> (3.26-5.78)	<b>4.83</b> (3.54-6.66)	<b>5.39</b> (3.79-7.64)	<b>6.15</b> (4.17-8.99)	<b>6.76</b> (4.45-10.0)
<b>2-hr</b>	<b>2.43</b> (1.96-3.04)	<b>2.79</b> (2.25-3.50)	<b>3.42</b> (2.75-4.30)	<b>3.99</b> (3.20-5.04)	<b>4.84</b> (3.78-6.40)	<b>5.54</b> (4.23-7.43)	<b>6.29</b> (4.64-8.65)	<b>7.10</b> (5.04-10.0)	<b>8.24</b> (5.63-12.0)	<b>9.15</b> (6.07-13.5)
<b>3-hr</b>	<b>2.74</b> (2.22-3.42)	<b>3.14</b> (2.54-3.92)	<b>3.87</b> (3.12-4.85)	<b>4.55</b> (3.66-5.73)	<b>5.61</b> (4.42-7.45)	<b>6.52</b> (5.01-8.75)	<b>7.50</b> (5.57-10.3)	<b>8.59</b> (6.13-12.2)	<b>10.1</b> (6.97-14.8)	<b>11.4</b> (7.61-16.7)
<b>6-hr</b>	<b>3.32</b> (2.71-4.12)	<b>3.80</b> (3.10-4.72)	<b>4.73</b> (3.84-5.89)	<b>5.63</b> (4.55-7.05)	<b>7.08</b> (5.65-9.41)	<b>8.35</b> (6.47-11.2)	<b>9.77</b> (7.32-13.4)	<b>11.3</b> (8.16-16.0)	<b>13.6</b> (9.45-19.8)	<b>15.5</b> (10.4-22.6)
<b>12-hr</b>	<b>3.96</b> (3.24-4.88)	<b>4.56</b> (3.73-5.62)	<b>5.73</b> (4.68-7.09)	<b>6.88</b> (5.59-8.55)	<b>8.73</b> (7.00-11.5)	<b>10.4</b> (8.07-13.8)	<b>12.2</b> (9.17-16.6)	<b>14.2</b> (10.3-19.9)	<b>17.1</b> (12.0-24.7)	<b>19.6</b> (13.2-28.3)
<b>24-hr</b>	<b>4.64</b> (3.83-5.69)	<b>5.39</b> (4.44-6.61)	<b>6.82</b> (5.60-8.39)	<b>8.21</b> (6.70-10.1)	<b>10.4</b> (8.40-13.7)	<b>12.3</b> (9.68-16.3)	<b>14.5</b> (11.0-19.7)	<b>16.9</b> (12.3-23.5)	<b>20.3</b> (14.3-29.1)	<b>23.2</b> (15.8-33.3)
<b>2-day</b>	<b>5.37</b> (4.45-6.53)	<b>6.26</b> (5.18-7.62)	<b>7.94</b> (6.55-9.69)	<b>9.53</b> (7.82-11.7)	<b>12.0</b> (9.72-15.6)	<b>14.2</b> (11.2-18.6)	<b>16.5</b> (12.6-22.3)	<b>19.2</b> (14.0-26.5)	<b>22.9</b> (16.2-32.6)	<b>26.1</b> (17.8-37.2)
<b>3-day</b>	<b>5.81</b> (4.83-7.04)	<b>6.79</b> (5.63-8.23)	<b>8.59</b> (7.11-10.4)	<b>10.3</b> (8.47-12.6)	<b>12.9</b> (10.5-16.7)	<b>15.2</b> (12.0-19.8)	<b>17.6</b> (13.5-23.6)	<b>20.4</b> (15.0-28.0)	<b>24.3</b> (17.2-34.3)	<b>27.4</b> (18.9-39.0)
<b>4-day</b>	<b>6.15</b> (5.13-7.43)	<b>7.19</b> (5.98-8.69)	<b>9.08</b> (7.53-11.0)	<b>10.8</b> (8.95-13.2)	<b>13.6</b> (11.0-17.5)	<b>15.9</b> (12.6-20.7)	<b>18.4</b> (14.1-24.6)	<b>21.2</b> (15.6-29.1)	<b>25.2</b> (17.9-35.5)	<b>28.4</b> (19.6-40.3)
<b>7-day</b>	<b>7.01</b> (5.87-8.43)	<b>8.15</b> (6.81-9.80)	<b>10.2</b> (8.51-12.3)	<b>12.1</b> (10.0-14.7)	<b>15.0</b> (12.2-19.1)	<b>17.5</b> (13.8-22.5)	<b>20.1</b> (15.4-26.6)	<b>23.0</b> (17.0-31.3)	<b>27.1</b> (19.3-37.9)	<b>30.4</b> (21.1-42.9)
<b>10-day</b>	<b>7.83</b> (6.56-9.37)	<b>9.03</b> (7.56-10.8)	<b>11.2</b> (9.33-13.4)	<b>13.1</b> (10.9-15.9)	<b>16.1</b> (13.1-20.4)	<b>18.6</b> (14.8-23.8)	<b>21.2</b> (16.3-27.9)	<b>24.1</b> (17.9-32.6)	<b>28.2</b> (20.2-39.2)	<b>31.5</b> (21.9-44.2)
<b>20-day</b>	<b>10.3</b> (8.69-12.3)	<b>11.7</b> (9.82-13.9)	<b>14.0</b> (11.7-16.7)	<b>16.0</b> (13.4-19.2)	<b>18.9</b> (15.4-23.6)	<b>21.3</b> (17.0-27.0)	<b>23.8</b> (18.4-31.0)	<b>26.5</b> (19.7-35.4)	<b>30.1</b> (21.7-41.5)	<b>33.0</b> (23.1-46.1)
<b>30-day</b>	<b>12.4</b> (10.5-14.7)	<b>13.9</b> (11.8-16.5)	<b>16.5</b> (13.9-19.6)	<b>18.6</b> (15.6-22.2)	<b>21.6</b> (17.6-26.7)	<b>24.0</b> (19.2-30.1)	<b>26.4</b> (20.5-34.1)	<b>28.9</b> (21.6-38.4)	<b>32.3</b> (23.3-44.2)	<b>34.9</b> (24.6-48.6)
<b>45-day</b>	<b>15.0</b> (12.7-17.7)	<b>16.8</b> (14.3-19.9)	<b>19.8</b> (16.7-23.4)	<b>22.2</b> (18.7-26.4)	<b>25.5</b> (20.8-31.2)	<b>28.0</b> (22.4-34.9)	<b>30.5</b> (23.7-39.0)	<b>33.0</b> (24.7-43.5)	<b>36.3</b> (26.2-49.3)	<b>38.7</b> (27.4-53.6)
<b>60-day</b>	<b>17.2</b> (14.6-20.3)	<b>19.4</b> (16.4-22.8)	<b>22.8</b> (19.3-26.9)	<b>25.5</b> (21.5-30.2)	<b>29.2</b> (23.8-35.5)	<b>31.9</b> (25.5-39.6)	<b>34.6</b> (26.9-44.0)	<b>37.2</b> (27.9-48.8)	<b>40.6</b> (29.4-54.9)	<b>43.0</b> (30.5-59.5)

<sup>1</sup> Precipitation frequency (PF) estimates in this table are based on frequency analysis of partial duration series (PDS).

Numbers in parenthesis are PF estimates at lower and upper bounds of the 90% confidence interval. The probability that precipitation frequency estimates (for a given duration and average recurrence interval) will be greater than the upper bound (or less than the lower bound) is 5%. Estimates at upper bounds are not checked against probable maximum precipitation (PMP) estimates and may be higher than currently valid PMP values.

Please refer to NOAA Atlas 14 document for more information.

[Back to Top](#)

### PF graphical

ENTERGY LOUISIANA, LLC  
NELSON POWER PLANT  
DOCUMENT NO. 2021-03526



PROJECT NO. 13603-006  
Date: 27 OCTOBER 2021

**ATTACHMENT 8.2**  
**EXISTING NELSON PLANT DRAWINGS**



Nelson Power Plant		6-hour (gallons)	12-hour (gallons)	24-hour (gallons)	2-day (gallons)	3-day (gallons)	4-day (gallons)	7-day (gallons)	10-day (gallons)	20-day (gallons)	30-day (gallons)
Average		5.63	6.88	8.21	9.53	10.3	10.8	12.1	13.1	16	18.6
High		7.05	8.55	10.1	11.7	12.6	13.2	14.7	15.9	19.2	22.2
Low		4.55	5.59	6.7	7.82	8.47	8.95	10	10.9	13.4	15.6
Areas (Square Feet)		42,107	Average	147,769	180,577	215,485	250,131	270,341	283,464	317,585	343,832
Unit 6		185,039	224,409	265,092	307,086	330,708	346,456	385,826	417,322	503,337	582,677
High		119,422	146,719	175,833	205,249	222,310	234,908	262,467	286,089	351,706	409,448
Low		40,418	49,392	58,940	68,417	73,945	77,534	86,867	94,046	114,865	133,531
Area 1 - Surge & Settling Tank Area		50,613	61,381	72,509	83,995	90,456	94,764	105,532	114,147	137,838	159,376
High		32,665	40,131	48,100	56,140	60,807	64,253	71,791	78,252	96,200	111,994
Low		8,468	10,348	12,349	14,334	15,493	16,245	18,200	19,704	24,066	27,977
Area 2 - Dewatering Bin Area		10,604	12,860	15,192	17,538	18,952	19,855	22,111	23,916	28,880	33,392
High		6,844	8,408	10,078	11,762	12,740	13,462	15,041	16,395	20,155	23,465
Low		98,882	120,837	144,196	167,380	180,904	189,686	212,518	230,082	281,016	326,681
Area 3 - Boiler Building Area		123,823	150,168	177,391	205,493	221,300	231,838	258,183	279,259	337,219	389,909
High		79,914	98,180	117,675	137,346	148,763	157,193	175,635	191,442	235,351	273,990
Low		2,413	2,413	2,413	2,413	2,413	2,413	2,413	2,413	2,413	2,413
Unit 6		6-hour	12-hour	24-hour	1	2	3	4	4	7	10
Duration		0.25	0.5	1	2	3	3	4	4	7	10
Duration in Days		274,517	274,517	274,517	274,517	274,517	274,517	274,517	274,517	274,517	274,517
Surge Capacity (Gallons)		0	0	0	0	0	0	2237	6153	6931	7272
Average Discharge/30-days (Gallons)		0	0	0	16285	18730	17985	15901	14281	11471	10272
High Discharge/30-days (Gallons)		0	0	0	0	0	0	0	0	1157	3859
Low Discharge/30-days (Gallons)		0	0	0	71,105	71,105	71,105	71,105	71,105	71,105	4498
10% PWV Gallons per Day		71,105	71,105	71,105	1,066,578	711,052	533,289	304,737	213,316	106,658	71,105
10% PWV x 30 days (Gallons)		8,532,624	4,266,312	2,133,156	0.00%	0.2%	0.3%	0.3%	0.5%	0.7%	1.1%
% of PWV		0.0%	0.0%	0.0%							1.4%

Nelson Power Plant		6-hour (gallons)	12-hour (gallons)	24-hour (gallons)	2-day (gallons)	3-day (gallons)	4-day (gallons)	7-day (gallons)	10-day (gallons)	20-day (gallons)	30-day (gallons)
Areas (Square Feet)	Unit 6	Average	High	11.5	13.7	15.6	16.7	17.5	19.1	20.4	21.6
	42,107 Average	Average	High	7	8.4	9.72	10.5	11	12.2	13.1	17.6
Surge Capacity (Gallons)	7.08	8.73	10.4	12	12.9	13.6	15	16.1	18.9	23.6	26.7
Average Discharge(30-days (Gallons))	9.41	11.5	13.7	15.6	16.7	17.5	19.1	20.4	23.6	26.7	26.7
High Discharge(30-days (Gallons))	5.65	7	8.4	9.72	10.5	11	12.2	13.1	15.4	17.6	17.6
Low Discharge(30-days (Gallons))	148,294	183,727	220,472	255,118	275,590	288,714	320,210	343,832	404,199	463,942	566,929
10% PWV (Gallons per Day)	42,107	50,828	62,673	74,662	86,149	92,510	97,635	107,686	115,583	135,685	155,068
10% PWV x 30 days (Gallons)	11.517	11.517	11.517	11.517	11.517	11.517	11.517	11.517	11.517	11.517	11.517
10% PWV x 30 days (Gallons)	High	82,559	98,353	111,994	119,891	125,634	137,120	146,453	169,426	191,681	191,681
10% PWV x 30 days (Gallons)	Low	40,562	50,254	60,304	69,781	75,380	78,970	87,585	94,046	110,558	126,352
10% PWV x 30 days (Gallons)	Average	10,649	13,131	15,643	18,050	19,403	20,456	22,562	24,217	28,428	32,489
Area 1 - Surge & Settling Tank Area	Average	14,154	17,298	20,607	23,465	25,119	26,322	28,729	30,684	35,98	40,161
Area 2 - Dewatering Bin Area	Average	8,498	10,529	12,635	14,620	15,793	16,546	18,351	19,704	23,164	26,473
Area 3 - Boiler Building Area	Average	124,349	153,329	182,660	210,762	226,569	238,863	263,452	282,772	331,950	379,371
Area 3 - Boiler Building Area	High	165,272	201,980	240,620	273,990	293,310	307,361	335,462	358,295	414,498	468,945
Area 3 - Boiler Building Area	Low	99,234	122,944	147,533	170,717	184,417	193,198	214,274	230,082	270,478	309,117
Unit 6											
Duration	6-hour	12-hour	24-hour	1	2	3	4	4	7	10	20
Duration in Days	0.25	0.5	1	2	3	4	4	7	7	10	20
Surge Capacity (Gallons)	<b>274,517</b>	<b>274,517</b>	<b>274,517</b>	<b>274,517</b>	<b>274,517</b>	<b>274,517</b>	<b>274,517</b>	<b>274,517</b>	<b>274,517</b>	<b>274,517</b>	<b>274,517</b>
Average Discharge(30-days (Gallons))	-	-	20,221,68	21,335,13	20,609,52	17,026,21	14,805,48	11,077,28	9,747,05	9,747,05	9,747,05
High Discharge(30-days (Gallons))	-	54,640,02	85,062,74	67,465,73	54,600,94	46,200,05	32,399,27	17,245,25	14,208,99	14,208,99	14,208,99
Low Discharge(30-days (Gallons))	-	-	-	-	357.77	3,549.17	6,527.53	6,931.47	6,484.11	6,247.50	6,247.50
10% PWV (Gallons per Day)	71,105	71,105	71,105	71,105	71,105	71,105	71,105	71,105	71,105	71,105	71,105
10% PWV x 30 days (Gallons)	8,532,624	4,266,312	2,133,156	1,066,578	711,052	533,289	304,37	213,316	106,658	71,105	71,105
% of PWV	0.0%	0.1%	0.40%	0.6%	0.8%	0.9%	1.1%	1.2%	1.6%	2.0%	2.0%



ATTACHMENT 8.5  
50 YEAR STORM EVENT

NELSON POWER PLANT  
DOCUMENT NO. 202103526



ATTACHMENT 8.6



ATTACHMENT 8.7



ATTACHMENT 8.8



---

Entergy  
RS Nelson Unit 6  
Project Number A13603.006  
Bottom Ash System Evaluation



SL Report No.: SL-016282  
Revision 1, For Information  
December 22, 2025

---

## **APPENDIX C – BOTTOM ASH PURGE WATER SUSPENDED SOLIDS ESTIMATE**

**Entergy Louisiana, LLC**

**Nelson 6 Generating Station, Unit 6**

**Document Number: 2021-04299**  
**Bottom Ash Purge Water Suspended Solids**  
**Estimate**

**Rev. 0**  
**October 26, 2021**



## Bottom Ash Purge Water Suspended Solids Estimate

### TABLE OF CONTENTS

Section	Title	Page No.
1	<b>PURPOSE AND SCOPE:</b>	3
2	<b>DESIGN INPUT:</b>	3
3	<b>ASSUMPTIONS:</b>	3
4	<b>METHODOLOGY &amp; ACCEPTANCE CRITERIA:</b>	3
5	<b>CALCULATIONS:</b>	3
6	<b>RESULTS:</b>	4
7	<b>REFERENCES:</b>	4
8	<b>ATTACHMENTS:</b>	4

## Bottom Ash Purge Water Suspended Solids Estimate

1.00 PURPOSE AND SCOPE:								
1.01	The R.S. Nelson Unit 6 is a coal fired unit located in Westlake, LA							
1.02	This calculation was performed to estimate the bottom ash purge water discharge to maintain TSS concentration of 0.3% or less.							
Item	Description	Reference	Unit of Measure	Data Value	Input (V/UV/EJ)			
<b>2.0 DESIGN INPUTS:</b>								
<b>2.1 Units 6</b>								
2.1.a	Unit 6 ash make rate, $M_{in}$	Bottom Ash Make Rate Design Basis, Rev. A.	t/day	258	UV			
2.1.b	Unit 6 Primary Active Wetted Bottom Ash System Volume, $V$	2021-03826, Wetted Bottom Ash Transport Water Volume Estimate	gallons	711,059	V			
<b>2.3 Bottom Ash Particle Size Distribution</b>								
2.3.a	Fraction of bottom ash particles $<300\text{ }\mu\text{m}$ interpolated from EPA particle size data, %removed	EPA-600/7-80-067, Table 8, pg 38	%wt	10.3%	UV			
2.3.b	Fraction of bottom ash particles $<75\text{ }\mu\text{m}$ , %fines	EPA-600/7-80-067, Table 8, pg 38	%wt	1.8%	UV			
Item	Description	Reference	Unit of Measure	Data Value				
<b>3.0 ASSUMPTIONS:</b>								
3.1	Particles $<75\text{ }\mu\text{m}$ are considered fines and only removed from the system in bottom ash purge water and water entrained in the ash in the trucks going to landfill				EJ			
3.2	No ash is present in the makeup water, $V_{mu}$ and water evaporated from the hopper and dewatering bins, $V_{evap}$				EJ			
3.3	Unit 6 evaporation from hopper and dewatering bins based on previous project experience prorated by unit N/A nameplate MW, $V_{evap}$		gpd	2995	EJ			
3.4	Percentage by weight of water entrained in ash trucked to landfill, %water	N/A	%	25%	EJ			
3.5	All particles other than fines are completely removed in the dewatering bins				EJ			
3.6	Dewatering bin systems will remove particles of 300 $\mu\text{m}$ size and above. Value based upon information from United Conveyor Corporation, the supplier of the system at WA Parish.		N/A	N/A	UV			
3.7	Bottom Ash System Total Suspended Solids Concentration Limit							
3.8.a	Total Suspended Solids Concentration to trigger erosion resistant pump materials, %TSS		%wt	0.30%	UV			
Item	Description	Variables						
<b>4.0 METHODOLOGY &amp; ACCEPTANCE CRITERIA:</b>								
4.1	The methodology for performing this calculation involves completing the following mass balance for all bottom ash handling systems on site:							
4.2	This calculation is acceptable if the resultant concentration of total suspended solids, %TSS, is less than or equal to the value in 3.8.a.							
Item	Description	Reference	Unit of Measure	Equation				
<b>5.0 CALCULATIONS:</b>								
5.1	Input of ash into system, $M_{in}$		lb/hr	$M_{in} = M_{in} \times 2000 / 24$				
	Unit 6		lb/hr	21500.0				
5.2	Input of fines into system, $F_{in}$		lb/hr	$F_{in} = M_{in} \times \% \text{fines}$				
	Unit 6		lb/hr	387.0				
5.3	Output of ash to landfill, $M_{landfill}$		lb/hr	$M_{landfill} = M_{in} - F_{in}$				
	Unit 6		lb/hr	21113.0				

Bottom Ash Purge Water Suspended Solids Estimate

5.4	Flow of water entrained in ash to landfill, $V_{\text{landfill}}$	gpd	$V_{\text{landfill}} = (M_{\text{landfill}} \times \% \text{water}) \times 24 / 8.338$		
	Unit 6	gpd	15192.9		
5.5	Makeup water flow into system, $V_{\text{mu}}$	gpd	$V_{\text{mu}} = V_{\text{purge}} + V_{\text{landfill}} + V_{\text{evap}}$		
	Unit 6	gpd	56543.4		
5.6	Fines included in the water entrained in ash to landfill, $F_{\text{landfill}}$	lb/hr	$F_{\text{landfill}} = F_{\text{in}} \times (1 - \% \text{removed})$		
	Unit 6	lb/hr	347.0		
5.7	Fines included in the bottom ash purge water, $F_{\text{purge}}$	lb/hr	$F_{\text{purge}} = F_{\text{in}} - F_{\text{landfill}}$		
	Unit 6	lb/hr	40.0		
5.8	Concentration of suspended solids in bottom ash purge water, recirculating water, and water entrained in ash to landfill, %TSS.	%	$\% \text{TSS} = F_{\text{purge}} / (V_{\text{purge}} / 24 \times 8.338)$		
	Unit 6	%	0.30%		
5.9	Bottom ash purge water flow, $V_{\text{purge}}$	gpd	$V_{\text{purge}} = F_{\text{purge}} / \% \text{TSS} \times 24 / 8.338$		
	Unit 6	gpd	38355.3		
5.10	Average fraction of primary wetted volume discharged per day, %PWV	%	$\% \text{PWV} = V_{\text{purge}} / V$		
	Unit 6	%	5.39%		
<b>Item</b>	<b>Description</b>	<b>Reference</b>	<b>Unit of Measure</b>	<b>Equation</b>	<b>Accept (Y/N)</b>
<b>6.0</b>	<b>RESULTS:</b>				
6.1	30-day rolling average discharge of bottom ash purge water from bottom ash system required to control fines concentration in Combined Unit 6 bottom ash system, %PWV		%PWV/day	5.39%	YES
<b>7.0</b>	<b>REFERENCES:</b>				
7.1	Program No. 032.435-16.0, Microsoft Excel for Office 365				
7.2	Bottom Ash Volume Calculation, 2021-03195				
7.3	EPA Report, EPA-600/7-80-067, Behavior of Coal Ash Particles in Water: Trace Metal Leaching and Ash Settling				
<b>8.0</b>	<b>ATTACHMENTS:</b>				
	None				

---

Entergy  
RS Nelson Unit 6  
Project Number A13603.006  
Bottom Ash System Evaluation



SL Report No.: SL-016282  
Revision 1, For Information  
December 22, 2025

---

## APPENDIX D – WATER BALANCE



*Entergy*

Entergy Louisiana, LLC  
Nelson 6

## Bottom Ash System Water Balance

Document No. NL-MSK-WB-005  
A13603.006  
26-Oct-2021  
Revision 0



Entergy Louisiana, LLC		Bottom Ash System Water Balance NL-MSK-WB-005, Rev 0 26-Oct-2021
Nelson 6 Project No.: A13603.006		

## **1.0 PURPOSE AND SCOPE**

The purpose of this calculation is to estimate discharge of bottom ash purge water due to regular inflows from wastestreams other than bottom ash transport water which, in total, exceed the capacity of the bottom ash system to accept in accordance with 40 CFR 423.13(k)(2)(i)(A)(2).

Flows around the following systems pertain to the scope of this water balance:

- Makeup Water Source from SRA pond
- Dewatering Bins
- Settling Tank
- Surge Tank
- Ash Loadout Area Sump
- Recirculation Pumps
- Boiler Blowdown
- Boiler Hopper Seal and Flushing Water
- Water Discharges (i.e. overflow outfall)

The flow of particular interest is the boiler blowdown. This is the only wastewater inflow to the bottom ash system. All other bottom ash system flows, including hopper seal and flushing water, are supplied by recycled transport water, from the recirculation pumps.

Entergy Louisiana, LLC		Bottom Ash System Water Balance NL-MSK-WB-005, Rev 0 26-Oct-2021
Nelson 6 Project No.: A13603.006		

## **2.0 DESIGN INPUT**

### 2.1 Boiler Main Steam for Blowdown Calculation

2.1a Full load boiler main steam based on Steam Generator Flow in accordance with Thermal Performance Data for Nelson Unit 6, 551 MW maximum guaranteed case.


### 2.2 Bottom Ash System Volumes

2.2a Bottom ash system primary wetted volume in accordance with Wetted Bottom Ash Volume Calculation, [PWV]	711,059 gallons	(Ref 8.3)
2.2b Bottom ash system surge capacity in accordance with Wetted Bottom Ash Volume Calculation, [SC]	274,517 gallons	(Ref 8.3)

<b>Entergy Louisiana, LLC</b>		<b>Bottom Ash System Water Balance</b>
<b>Nelson 6</b>		<b>NL-MSK-WB-005, Rev 0</b>
<b>Project No.: A13603.006</b>		<b>26-Oct-2021</b>

## **ATTACHMENT 9.1**

### **Water Balance Diagram**



<b>Entergy Louisiana, LLC</b>  <b>Nelson 6</b> <b>Project No.: A13603.006</b>		<b>Bottom Ash System Water Balance</b>  <b>NL-MSK-WB-005, Rev 0</b> <b>26-Oct-2021</b>
--	---	---

## **ATTACHMENT 9.2**

### **Summary of Water Balance Calculation**

**Potential Discharge from Bottom Ash System Resulting from Boiler Blowdown**

		Water Inputs			Water Discharges								
MW Load	Main Steam, (MS) [lb/hr]	Boiler Blowdown, (%MS), [%]	Boiler Blowdown, (BD-flow) [gpm]	Boiler Blowdown, (BD-vol) [gallons]	SRA Pond Rainfall, (RF-vol) [gallons]	SRM Makeup, (MU-vol), [gallons]	Ash to Landfill, (Ash-vol), [tons]	Water in Pyrites, (Ash) [gallons]	Dewatering Bin	Evaporation, (H-vol), [gallons]	Surge Capacity, (SC), [gallons]	Total Discharge, (D), [gallons]	Fraction of PWV per day, [%]
From Westinghouse Thermal Kit	Assumption	Calculated	Calculated	Rainfall Estimate	Calculated	Estimate	Calculated	Assumption	Calculated	Assumption	Calculated	Calculated	Calculated
551	3,796,838	1%	75.9	3,278,632	0	0	8172.85	490,096	216,000	43,200	2,529,336	274,517	720

<b>Entergy Louisiana, LLC</b>  <b>Nelson 6</b> <b>Project No.: A13603.006</b>		<b>Bottom Ash System Water Balance</b>  <b>NL-MSK-WB-005, Rev 0</b> <b>26-Oct-2021</b>
--	---	---

## **ATTACHMENT 9.3**

**Nelson Ash Make Rate Design Basis.xlsx**

**Table 1: Unit Make-Rate Calculation (Equipment Sizing)**

Plant-Unit	Unit type	Gross Rating (MW)	Heat Rate <sup>5</sup> (Btu/kWh)	Btu Value <sup>1</sup> (Btu/lb)	Total Coal Burned (tons/hr)	Number of Coal Mills	Ash % <sup>1</sup>	Total Ash (tph)	Percent Fly Ash <sup>2</sup>	Percent Bottom Ash <sup>2</sup>	Fly Ash (tph)	Bottom Ash (tph)	Economizer ash <sup>3</sup> (tph)	Pyrites <sup>4</sup> (tph)
Nelson Unit 6	Pulverized Coal	551	11,340	8,985	347.71	6	7.73%	26.88	60%	40%	16.13	10.75	1.34	0.60

Notes (D) = Design Input, U = Unverified, V = Verified, J = Engineering Judgment

1) Per June 22, 2021 e-mail, from Lauren Carpenter

2) Pulverized coal boiler has an ash distribution of 60%/40% fly ash/bottom ash per client request.

3) Per Steam: It's Generation and Use by B&W - economizer ash is assumed to be 5% of total ash. Economizer ash is not handled within the bottom ash system.

4) Pyrite production based on an assumed production rate of 200 lbs/hr per coal mill.

5) Heat Rate is assumed to be 11,340 Btu/kWh in accordance with 2007 NETL coal plant database information.

(D)  
(D)  
(D)  
(U)  
(U)